



POTRDILO O PRESKUŠANJU

TEST CERTIFICATE



Št. potrdila:
Certificate No.:

IZV- 1496/19

Veljavnost:
Validity:

18. 11. 2024

Naročnik:
Customer:

DOMIR – TRGOVINA, PROIZVODNJA, INŽENIRING, d.o.o.,
Loka pri Mengšu, Testenova 53, 1234 Mengeš

Proizvajalec:
Manufacturer:

PEXAL d.o.o.,
Dobeno 80a, 1234 Mengeš

Proizvod:
Product:

Cevi PEX-b s spojnimi elementi s stisljivo spono
Tube PEX-b with press fittings

Standard:
Norm:

DVGW W 534: *Rohrverbinder und Rohrverbindungen in der Trinkwasser-Installation*
SIST ISO 1167-1: 2006: *Plastomerne cevi, fittingi in spoji za pretok tekočin in plinov*
Thermoplastics pipes, fitting and assemblies for the conveyance of fluids
SIST EN ISO 15875-2: 2004: *Cevni sistemi iz polimernih materialov za napeljave z vročo in hladno vodo – Zamreženi polietilen (PE-X) – 2. del: Cevi*

Tip, model:
Types, Model:

PEXAL PEX-b

maksimalni obratovalni tlak / *maximum operating pressure*: MOP 6 bar
maksimalna obratovalna temperatura / *maximum operating temperature*: +95°C
velikost cevi (mm) / *pipe size (mm)*: 16×2; 18×2; 20×2; 25×2,5; 32×3; 40×3,5; 50×4

Izjava / Declaration:

Preskusni vzorci so bili preskušani in pregledani po zahtevah naročnika. Preskus je bil izveden v skladu s predpisom DVGW W 534 (točka 12.3, 12.4 in 12.7) ter standardoma ISO 1167-1 Ugotavljanje odpornosti proti notranjemu tlaku-1.del: Osnovna metoda, ter EN ISO 15875-2 (točki 7, 8).

Test samples have been tested and examined in accordance with the client's requirements. The test was performed in pursuance with DVGW W 534 (paragraphs 12.3 and 12.4), ISO 1167-1 Determination of the resistance to internal pressure-part 1: General method, and EN ISO 15875-2 (paragraphs 7, 8).

Poročilo št.: / Test report No.:

79879 / 19

Datum / Date : 18. 11. 2019

Zaključek / Conclusion:

Ugotovljeno je bilo, da preskusni vzorci izpolnjujejo tehnične zahteve. Proizvodu je priložena spremna dokumentacija, ki vsebuje ustrezna navodila za uporabo.

It has been established that the test samples meet the technical requirements. Product accompanied by supporting documentation, which include adequate instructions for use.

Opomba : /
Note:

Direktor :
Director

Ljubljana, 18. 11. 2019
Place, date

Dr.-Ing. Miro Uran, univ. dipl. inž.



[Handwritten signature]



POTRDILO O PRESKUŠANJU

TEST CERTIFICATE



Št. potrdila:
Certificate No.:

IZV- 1497/19

Veljavnost:
Validity:

18. 11. 2024

Naročnik:
Customer:

DOMIR – TRGOVINA, PROIZVODNJA, INŽENIRING, d.o.o.,
Loka pri Mengšu, Testenova 53, 1234 Mengeš

Proizvajalec:
Manufacturer:

PEXAL d.o.o.,
Dobeno 80a, 1234 Mengeš

Proizvod:
Product:

Cevni razdelilnik za ogrevalne sisteme
Manifold for heating systems

Standard:
Norm:

DVGW W 534: *Rohrverbinder und Rohrverbindungen in der Trinkwasser-Installation*

Tip, model:
Types, Model:

Cevni razdelilnik 2 -12 vej / Manifold 2 – 12 branches

maksimalni obratovalni tlak / *maximum operating pressure*: MOP 3 bar

maksimalna obratovalna temperatura / *maximum operating temperature*:

+90°C

vhodni priključek 1", izhodni priključki ¾" / *input connection 1", output connections ¾"*

Izjava / Declaration:

Preskusni vzorci so bili preskušani in pregledani po zahtevah naročnika. Preskus je bil izveden v skladu s predpisom DVGW W 534 (točki 12.3 in 12.4).

Test samples have been tested and examined in accordance with the client's requirements. The test was performed in pursuance with DVGW W 534 (paragraphs 12.3 and 12.4).

Poročilo št.: / Test report No.:

79880 / 19

Datum / Date : 18. 11. 2024

Zaključek / Conclusion:

Ugotovljeno je bilo, da preskusni vzorci izpolnjujejo tehnične zahteve. Proizvodu je priložena spremna dokumentacija, ki vsebuje ustrezna navodila za uporabo.

It has been established that the test samples meet the technical requirements. Product accompanied by supporting documentation, which include adequate instructions for use.

Opomba : /
Note:

Direktor :
Director

Ljubljana, 18. 11. 2019
Place, date

Dr.-Ing. Miro Uran, univ. dipl. inž.



POTRDILO O PRESKUŠANJU TEST CERTIFICATE



Št. potrdila:
Certificate No.:

IZV- 1495/19

Veljavnost:
Validity:

18. 11. 2024

Naročnik:
Customer:

DOMIR – TRGOVINA, PROIZVODNJA, INŽENIRING, d.o.o.,
Loka pri Mengšu, Testenova 53, 1234 Mengeš

Proizvajalec:
Manufacturer:

PEXAL d.o.o.,
Dobeno 80a, 1234 Mengeš

Proizvod:
Product:

Cevi PEX / AI / PEX s spojnimi elementi s stisljivo spono
Tube PEX / AI / PEX with press fittings

Standard:
Norm:

DVGW W 534: *Rohrverbinder und Rohrverbindungen in der Trinkwasser-Installation*
SIST ISO 1167-1: 2006: *Plastomerne cevi, fittingi in spoji za pretok tekočin in plinov*
Thermoplastics pipes, fitting and assemblies for the conveyance of fluids

Tip, model:
Types, Model:

MULTISTABILE PEX / AI / PEX

maksimalni obratovalni tlak / maximum operating pressure: MOP 10 bar
maksimalna obratovalna temperatura / maximum operating temperature: +95°C
velikost cevi (mm) / pipe size (mm): 16×2; 18×2; 20×2; 25×2,5; 32×3

Izjava / Declaration:

Preskusni vzorci so bili preskušani in pregledani po zahtevah naročnika. Preskus je bil izveden v skladu s predpisom DVGW W 534 (točki 12.3 in 12.4) in standardom SIST ISO 1167-1 Ugotavljanje odpornosti proti notranjemu tlaku-1.del: Osnovna metoda.

Test samples have been tested and examined in accordance with the client's requirements. The test was performed in pursuance with DVGW W 534 (paragraph 12.3 and 12.4) and ISO 1167-1 Determination of the resistance to internal pressure-part 1: General method.

Poročilo št./ Test report No.:

79878 / 19

Datum / Date : 18. 11. 2019

Zaključek / Conclusion:

Ugotovljeno je bilo, da preskusni vzorci izpolnjujejo tehnične zahteve. Proizvodu je priložena spremna dokumentacija, ki vsebuje ustrezna navodila za uporabo.

It has been established that the test samples meet the technical requirements. Product accompanied by supporting documentation, which include adequate instructions for use.

Opomba : /
Note:

Direktor :
Director

Ljubljana, 18. 11. 2019
Place, date

Dr.-Ing. Miro Uran, univ. dipl. inž.



INSTITUT ZA VARILSTVO
Welding Institute